

| Quantity | OCCUPANT LOAD: | | | | | | |
|----------|----------------------|------|----|---|-----|---|----------------|
| 1 | ACCESSIBLE TOILET | 100 | SF | ÷ | 0 | = | 0 PEOPLE 100 |
| 1 | DISPLAY | 100 | SF | ÷ | 30 | = | 4 PEOPLE 100 |
| 1 | ELECTRICAL ROOM | 100 | SF | ÷ | 0 | = | 0 PEOPLE 100 |
| 1 | ENTRY | 100 | SF | ÷ | 0 | = | 0 PEOPLE 100 |
| 1 | EX ACCESSIBLE TOILET | 100 | SF | ÷ | 0 | = | 0 PEOPLE 100 |
| 1 | EXISTING TOILET | 100 | SF | ÷ | 0 | = | 0 PEOPLE 100 |
| 1 | EXIT CORRIDOR | 100 | SF | ÷ | 0 | = | 0 PEOPLE 100 |
| 1 | HALLWAY | 100 | SF | ÷ | 0 | = | 0 PEOPLE 100 |
| 1 | MECHANICAL ROOM | 100 | SF | ÷ | 0 | = | 0 PEOPLE 100 |
| 1 | OFFICE | 100 | SF | ÷ | 100 | = | 1 PEOPLE 100 |
| 1 | OFFICE/STOCKROOM | 100 | SF | ÷ | 300 | = | 1 PEOPLE 100 |
| 1 | SECURITY CLOSET | 100 | SF | ÷ | 300 | = | 1 PEOPLE 100 |
| 1 | SHOW WINDOW | 100 | SF | ÷ | 0 | = | 0 PEOPLE 100 |
| 1 | STOCKROOM | 100 | SF | ÷ | 300 | = | 1 PEOPLE 100 |
| 1 | | 57 | SF | ÷ | 300 | = | 1 PEOPLE 57 |
| 1 | | 71 | SF | ÷ | 300 | = | 1 PEOPLE 71 |
| 1 | STORAGE | 100 | SF | ÷ | 300 | = | 1 PEOPLE 100 |
| 1 | TRAINING ROOM | 100 | SF | ÷ | 100 | = | 1 PEOPLE 100 |
| 1 | VOID | 100 | SF | ÷ | 0 | = | 0 PEOPLE 100 |
| | | 1828 | | | | | 12 PEOPLE 1828 |

GRID LINES WONT TURN OFF
ONLY WANT THE BLUE TOTAL
LINE VISIBLE.

COMBINE INTO ONE LINE ITEM SO IT WOULD BE
228 SF ÷ 300 = 1 (as it is now additional
people will be added to occupancy load
that I don't need). NEEDS TO LOOK LIKE
THIS—

STOCKROOM 200 SF ÷ 300 = 1 PEOPLE