
 Flange

NOTES:

(b) FLANGES TO BE COMPATIBLE TO MATCHING EQUIPMENT AND VALVING, ETC. WHERE EQUIPMENT AND/OR VALVE FLANGES DO NOT MATCH API-605, THESE FLANGES SHALL BE OF SPECIAL DESIGN.

1/2"	to	1 1/2"	FLANGE SW, 150#, RF, CS, ASTM-A105, bore to match pipe
4"	to	24"	FLANGE WN, 150#, RF, CS, ASTM-A105, bore to match pipe
26"	to	30"	FLANGE WN, 150#, RF, CS, ASTM-A105, bore to match pipe, ASME B16.47 SERIES B
2"	to	3"	FLANGE WN, 300#, RF, CS, ASTM-A105, bore to match pipe
2"	to	24"	ORIFICE WN, 300#, RF, 1.2" FPT TAPS, CS, ASTM-A105, bore to match pipe

 Gasket

2"	to	24"	GASKET, SWG, 1/8" THK, 304SS WITH GRAPHITE FILLER, FLEXITALLIC-STYLE CG or equal
4"	to	24"	GASKET, SWG, 1/8" THK, 304SS WITH GRAPHITE FILLER, FLEXITALLIC-STYLE CG or equal
1/2"	to	3"	GASKET, SWG, 1/8" THK, 304SS WITH GRAPHITE FILLER, FLEXITALLIC-STYLE CG or equal

 Nipple

NOTES:

(l) PIPE NIPPLES TO MATCH PIPE SCHEDULE

3/4"	to	3/4"	PIPE NIPPLE, 3" LG, SCH80, PE, ASTM-A106, GR. B
1/2"	to	1/2"	PIPE NIPPLE, 3" LG, SCH80, TBE, ASTM-A106, GR. B

 Olet
