AB
1771-IAD
RACK 1
SLOT 2
120V AC/DC 16-PT INPUT
PLC1

00	01	02	03	04	05	06	07	10	11		
I:002/00	I:002/01	I:002/02	I:002/03	I:002/04	I:002/05	I:002/06	I:002/07	I:002/10	I:002/11		
IN 00	IN 01	IN 02	IN 03	IN 04	IN 05	IN 06	IN 07	IN 10	IN 11		
I:002/00	I:002/01	I:002/02	I:002/03	I:002/04	I:002/05		I:002/07	I:002/10			
CAB5 TB2	CAB5 TB2	CAB5 TB2	CAB5 TB2	CAB5 TB2	CAB5 TB2		CAB5 TB2	CAB5 TB2			
BANK #1 FIBER WASTE REMOVAL BLOWER START HS100BR REMOTE	BANK #1 FIBER WASTE REMOVAL BLOWER STOP HS100BS	BANK #2 FIBER WASTE REMOVAL BLOWER START HS1001BR REMOTE	BANK #2 FIBER WASTE REMOVAL BLOWER STOP HS1001BS	TUB OUTLET TEMPERATURE NOT LOW(ALARM)	TUB INLET TO HEATER FLOW NOT LOW (TRIP)	SPARE	COMBUSTION BLOWER RUNNING	INSTRUMENT AIR PRESSURE NOT LOW (IPS)			
FIELD HS100BR	FIELD HS100BS	FIELD HS1001BR	FIELD HS1001BS	FIELD D5681TS	FIELD D2150FS		MCC MS101	CAB5 D006PS	FIELD D007PS	FIELD D008PS	FIELD D009PS
CYCLE START	STOP	START	STOP	TUB OUTLET TEMP	TUB INLET		AIR PRESS OKAY		ALT AIR OKAY	ALT AIR 2	ALT AIR 2
JBOX1 TB1	JBOX1 TB1	JBOX1 TB1	JBOX1 TB1	JBOX1 TB1	JBOX1 TB1		JBOX1 TB1	JBOX1 TB1			
1	2	3	4	5	6						

FIELD D5691TS
TUB OUTLET TEMP
FIELD D5701TS
TUB OUTLET TEMP