



CHANGE ARROW SIZE USING PROPERTIES DIALOG BOX



EXISTING PANEL
600A, 120V/208V
c/w TVSS



EXISTING 112kVA
TRANSFORMER
600V-120V/208V

NEW 300A, 3P SWITCH (MCCB ENCLOSURE, 35kA)

3
NEW 225kVA
TRANSFORMER
600V-120V/208V
K-13, TEMP. RISE 80°C
PROVIDE HOUSEKEEPING PAD

NEW DISTRIBUTION PANEL 'PP-WTL-D' 800A, 120V/208V,
3PH, 4W, 22kA, c/w TVSS (I-LINE HCP-SU)
PROVIDE UNISTRUT SUPPORT
STRUCTURE MOUNTED TO FLOOR,

EXISTING DIST. PANEL
'DP-P2UPSA'

Command:
Command: *Cancel*
Command: *Cancel*