


NOTES:

1. ALL EXISTING PIPING & EQUIPMENTS ARE SHOWN ON LIGHT LINES.
2. REMOVE EXISTING DEAERATOR AND ASSOCIATED PIPING AS SHOWN AND POWER BACK TO THE PANEL.
3. SAVE BOILER FEED PUMP SERVING BIO-MASS BOILER TO BE RE-INSTALLED WITH NEW DEAERATOR.
4. INSTALL A NEW ISOLATION VALVE AT BIO-MASS BOILER FEED WATER PUMP DISCHARGE (APPROX. 2") VIF LOCATION AND SIZE OF THE PIPE
5. RETURN ALL OTHER BOILER FEED PUMPS TO THE OWNER
6. ALL WORK SHOWN ON THIS DRAWING SHALL BE INCLUDED IN THE BASE BID.



Federal Bureau of Prisons
Washington, D.C.
Contract No. DJBP0100N8A30002
Order No. DJBP0100N8A30002
FEDERAL BUREAU OF PRISONS

PREPARED BY:



PROPERTY OF THE UNITED STATES
GOVERNMENT SENSITIVE BUT UNCLASSIFIED
Properly destroy documents/media when
no longer needed.

NOT RELEASED FOR
CONSTRUCTION

NO.	REVISION	DATE

PROJECT : DEAERATOR
REPLACEMENT
FEDERAL CORRECTIONAL
INSTITUTE
PETERSBURG, VIRGINIA

SHEET TITLE : EXISTING POWER PLANT
DEMOLITION
FLOOR PLAN

DRAWN BY: AB	JOB NUMBER 2018-14-003	APPROVED BY: XXX
CHECKED BY: AB	DIVISION HEAD	M101
DATE: 01/19/2015	PROJ. MANAGER	
SCALE: AS NOTED	SHEET 2 OF 9	