

NUMBERED NOTES:

- 1 CONNECT TO 20 AMP 480 VOLT 3 PHASE CHARGING UNIT.
- 2 PROVIDE 100 AMP 480 VOLT 3 PHASE POWER TO COOLER PROVIDED BY OTHERS.
- 3 IN THIS ROOM PROVIDE 120 VOLT POWER TO SPRINKLER SYSTEM FLOW/TAMPER SWITCH AND OUTSIDE BELL. CONNECT ELECTRIC SERVICE GROUND TO BUILDING WATER SERVICE IN THIS ROOM.
- 4 CONNECT TO OVERHEAD DOOR OPERATOR.
- PROVIDE OUTLET AT 48" FOR DOCK LIGHT PROVIDED BY OTHERS.