



- CODED NOTES:**
- PULL PRIMARY CABLE THRU THE EXISTING DUCT BANK FROM THE PRIMARY TERMINATION ENCLOSURE AT THE METERING VAULT TO THE SUBSTATION IN UTILITY ROOM 002.
  - EXTEND EXISTING UNDERGROUND 1" PVC CONDUIT TO NEW POLE FOUNDATION. PROVIDE FOUNDATION, POLE, LIGHTING FIXTURES AND RECEPTICAL. SEE DETAIL B/SE-1.
  - CATHODIC PROTECTION SYSTEM ANODES WIRE TO RECTIFIER ADJACENT TO PANEL RP2K, MAINT. RM. 135; SEE DWG. E-3. FOR ANODE INSTALLATION DETAILS, SEE DWG. D-18531, CATHODIC PROTECTION SYSTEM INSTALLATION PLAN.
- GENERAL NOTES**
- OUTDOOR LIGHTING CIRCUIT NUMBERS ARE PANEL LP5K. SEE DWG. E-14 FOR CONTROL DETAILS.

AS-BUILTS			W/M/TLS
NO.	DESCRIPTION	DATE	BY
REVISIONS			
<b>STILSON &amp; ASSOCIATES, INC.</b>			
ENGINEERING • ARCHITECTURE • ENVIRONMENTAL			
COLUMBUS CLEVELAND			
WORTHINGTON FOODS, INC.			
ZANESVILLE, PHASE 1			
ELECTRICAL SITE PLAN			
DRAWN	TES	PROJECT NO.	9231-4029-40
DESIGNED	JHB	CONTRACT	
CHECKED	JPM	SHEET	OF
APPROVED		DRAWING NUMBER	SE-1
APPROVED		W.P. FILE NUMBER	D-15974
DATE	12-18-92		
SCALE	1"=40'-0"		