









6

ADDRESSABLE FIRE ALARM SYSTEM

S.NO	SYMBOLS	DESCRIPTION	MAKE	MOUNTING HEIGHT
1		HEAT DETECTOR RATE OF TEMPERATURE TYPE	HONEY WELL/ GST /GENT	ON FALSE CEILING
2		SMOKE DETECTOR NON IONISATION TYPE.	HONEY WELL/ GST /GENT	ON FALSE CEILING
3		INDICATES ALARM SOUNDER	HONEY WELL/ GST /GENT	ON WALL AT 7'-0"F.F.L
4		INDICATES MANUAL STATION ON M.S JUNCTION BOX 4"x4"-16 SWG	HONEY WELL/ GST /GENT	ON WALL AT 3'-6"F.F.L
5		INDICATES FIRE ALARM JUNCTION BOX MADE OF M.S SHEET 16 SWG 4"x7"x4"DEEP WITH COVER TO PULL FIRE ALARM CABLES	LOCAL	6" TO 9" BELOW SLAB BUT ABOVE FALSE CEILING
6		INDICATES FIRE ALARM CONTROL PANEL	HONEY WELL/ GST /GENT	ON WALL AT 4'-0"F.F.L
7		INDICATES WIRING IN 1" DIA PVC CONDUIT FOR FIRE ALARM SYSTEM SYSTEM	-SHAVYL -DELTA GOLD -BETA	ON SLAB AFC
8		18" Ø JET FAN		